

Broadcast Engineering Consultants India Limited
(Under Ministry Of Information and Broadcasting)
C-56A/17, Sector-62, Noida-201307

BECIL/NMW/MEP/2020/01

Date: 20.03.2020

Corrigendum No. 1

Subject: Corrigendum to Request for Proposal for “Civil, Interior, IT, MEP & other related work of New Media Wing (NMW) at 11th Floor, Sochna Bhawan, New Delhi.

Reference: RFP Ref No: BECIL/NMW/MEP/2020/01 dated: 19.03.2020

RFP has been revised as given below:

S.N.	Clause/ Appendix/ Page	Description/Queries	Amended Clause/Clarifications
1	Point no. 5, under the heading “Eligibility Criteria” at page no. 14	<p>Description:</p> <p>The bidders should have Average Turnover of INR 3 Crores for the last 3 Financial Year (2016-17, 2017-18 and 2018-19) Copy of Audited Financial Statement (Annual Account) should be submitted for the mentioned three years.</p> <p>Example: if a bidder is having turnover of INR 2.5 Crores for Financial Year 2016-17, INR 4.5 Crores for Financial Year 2017-18 and INR 2 Crores for Financial Year 2018-19, then average turnover for above mentioned clause (clause no. 5 of Eligibility Criteria) calculated as following.</p> <p>Average Turnover for last 3 years (in INR) = ((Turnover for FY 2016-17) + (Turnover for FY 2016-17) + (Turnover for FY 2016-17))/3 = (2.5 Crores + 4.5 Crores + 2 Crores)/3 = 9 Crores/3 = 3 Crores</p> <p>As per above calculation bidder will be declared qualified for the clause no. 5 under Eligibility Criteria.</p>	<p>Amended Clause:</p> <p>The bidders should have Average Turnover of INR 1.25 Crores for the last 3 Financial Year (2016-17, 2017-18 and 2018-19) Copy of Audited Financial Statement (Annual Account) should be submitted for the mentioned three years.</p> <p>Example: if a bidder is having turnover of INR 1 Crores for Financial Year 2016-17, INR 1.50 Crores for Financial Year 2017-18 and INR 1.25 Crores for Financial Year 2018-19, then average turnover for above mentioned clause (clause no. 5 of Eligibility Criteria) calculated as following.</p> <p>Average Turnover for last 3 years (in INR) = ((Turnover for FY 2016-17) + (Turnover for FY 2016-17) + (Turnover for FY 2016-17))/3 = (1 Crores + 1.50 Crores + 1.25 Crores)/3 = 3.75 Crores/3 = 1.25 Crores</p> <p>As per above calculation bidder will be declared qualified for the clause no. 5 under Eligibility Criteria.</p>
2	Point no. D.01, under the heading “Civil, Interior and	<p>Description: Main Entrance Door - Size 1500x2400MM</p>	<p>Clarification: Kindly consider the makes provided in the List of makes for this item.</p>

	Plumbing works” at page no. 26	Queries: Patch fittings make given in item is not matching with drawing.	
3	Point no. D.02, under the heading “Civil and Interiors” at page no. 26	Description: Framed Double Door Queries: a) door closer of YALE make but model no. is not given. b) Handle detail and size are not matching with the drawing.	Clarifications: a) Kindly consider the makes provided in the List of makes for this item. b) Kindly refer the drawing and consider makes provided in the List of makes for this item.
4	Point no. D.04, under the heading “Civil, Interior and Plumbing works” at page no. 26	Description: Frameless Glazed Door Type 2 Queries: Description of item is not matching with drawing furthermore all doors head description of item needs to be re-checked with drawing.	Amended Clause: Clause no. D.04 can be read as follows: D.04: FLU SH DOORS, LAMINATED WITH VISION PANEL: P&F Semi solid core laminated DOOR formed out of 25X 100 mm wide CPTW frame 6 mm thick comm. ply skins, and faced both sides with 4 mm thick Maple/Steem Beech wood veneer to form overall thickness of 40 mm. 3/6mm grooves. Including 50X 100 section Maple/Steem Beech wood chowkhat. All wood and veneered faces to be stained and melamine polished to Architect’s approval. Door to have vision panel formed of 8/10mm toughened glass. Sizes of cut-outs as per detailed drawing. Complete with all hardware including locks, door closer, doorstoppers etc as required. Hardware set as per item number F.5 above. Overall door size to be 2400/2550 x 1200 mm. Refer to Door Schedule drawing
5	Point no. C.02, under the heading “Civil, Interior and Plumbing works ” at page no. 24	Description: Water Closets Type II Queries: This model of WC as checked is discontinued now.	Clarification: This item is rate only and consider make for item no. C.02 as Kolher / American standard.
6	Point no. 3.1, under the heading “IT Networking” at page no. 58	Description: 42U Networking Rack (800 x1000 mm) with accessories for data (Cisco Make) Networking rack. Queries: Cisco make networking rack is not available in market.	Clarification: Consider the make options as Vakrack, Data rack and MTS for this item.

7	Point no. XI "Supply & Installation of UPS", under the heading "Electrical Work" at page no. 42	<p>Description: Supply & Installation of UPS</p> <p>Queries: Backup requirement is not given.</p>	<p>Clarification: Consider a backup time of 20 minutes.</p>
8	Point no. XII "Allied Works", under the heading "Electrical Work" at page no. 43	<p>Description: Allied works</p> <p>Queries: Backup requirement is not given.</p>	<p>Clarification: Consider a backup time of 20 minutes.</p>
9	Point no. F.28 "Built in Storage", under the heading "Civil, Interior and Plumbing works" at page no. 29	<p>Description: Personal Locker Units</p> <p>Queries: Material details of construction needs to be provided.</p>	<p>Clarification: Commercial board with laminate finish.</p>
10	General	-	Bidders are requested to refer the updated Bill of Material (BoQ) and Unpriced BoQ on BECIL online tendering website (https://becil.euniwizarde.com).
11	General	-	Bidders already submitted their bids are requested to resubmit there bids considering modifications made via corrigendum else bid will be auto rejected by the online bidding portal.

Note: Other Terms and conditions of the above said RFP will remain same.

s/d

Deputy General Manager